



Per ogni ulteriore collettore aggiuntivo è necessario aggiungere un kit RAC+I, composto dai due raccordi dritti doppi (indicazione 9). Si consiglia di collegare alla mandata A e al ritorno B due tubi di rame da 22 con bloccaggio a stringere.

*For each additional collector it's necessary to add one RAC+I kit, composed by n° 2 double elbows (indication 9). We advise to connect delivery A and reversion B 2 copper pipes of 22 with fastening locking.*

**RAC+1**



Legenda <i>Legend</i>	Descrizione <i>Description</i>	Tipo <i>Size</i>
<b>A</b>	Uscita (andata) acqua calda dai collettori verso il bollitore <i>Hot water outlet (delivery) from the collectors towards boiling device</i>	
<b>B</b>	Ingresso (ritorno) acqua fredda dal bollitore verso i collettori <i>Cold water input (return) from boiling device to the collectors</i>	
<b>C</b>	Collettore solare - <i>Solar collector</i>	
<b>0</b>	Raccordo dritto femmina - <i>Female straight fitting</i>	22 x 3/4"
<b>1</b>	Riduzione - <i>Adapter</i>	3/4" x 1/2"
<b>2</b>	Valvola sfogo aria manuale - <i>Manual valve for air outlet</i>	1/2"
<b>3</b>	Pozzetto porta sonda in rame - <i>Copper probe trap</i>	1/2"
<b>4</b>	Raccordo dritto maschio - <i>Male straight fitting</i>	22 x 3/4"
<b>5</b>	Croce - <i>Cross</i>	3/4" x 3/4" x 3/4" x 3/4"
<b>6</b>	Raccordo dritto femmina - <i>Female straight fitting</i>	22 x 1/2"
<b>7</b>	Valvola di sicurezza a 6 atm. maschio - <i>Male 6 atm security valve</i>	1/2"
<b>8</b>	Rubinetto carico-scarico liquido - <i>Filling and emptying ball valve</i>	1/2"
<b>9</b>	Raccordo dritto doppio <b>(KIT RAC+I)</b> - <i>Double straight fitting (RAC+I KIT)</i>	22 x 22